


HONOLULU FIRE DEPARTMENT
CITY AND COUNTY OF HONOLULU

636 South Street
Honolulu, Hawaii 96813-5007
Phone: 808-723-7139 Fax: 808-723-7111 Internet: www.honolulu.gov/hfd

MUFI HANNEMANN
MAYOR



July 20, 2010

SSFM INTERNATIONAL, INC.
RECEIVED

JUL 23 2010

JKE

FILE

KENNETH G. SILVA
FIRE CHIEF

ROLLAND J. HARVEST
DEPUTY FIRE CHIEF

Mr. Jared Chang
Project Planner
SSFM International, Inc.
501 Sumner Street, Suite 620
Honolulu, Hawaii 96817

FILE COPY

Dear Mr. Chang:

Subject: Preassessment Consultation for Draft Environmental Assessment
KIWC Kalaeloa Precast Yard
Tax Map Key: 9-1-013: 038 Portion

In response to your letter of July 14, 2010, regarding the above-mentioned subject, the Honolulu Fire Department (HFD) reviewed the material provided and requires that the following be complied with:

1. Fire department access roads shall be provided such that any portion of the facility or any portion of an exterior wall of the first story of the building is located not more than 150 ft (46 m) from fire department access roads as measured by an approved route around the exterior of the building or facility. (National Fire Protection Association [NFPA] 1; Uniform Fire Code [UFC]TM, 2006 Edition, Section 18.2.3.2.2.)

A fire department access road shall extend to within 50 ft (15 m) of at least one exterior door that can be opened from the outside and that provides access to the interior of the building. (NFPA 1; UFCTM, 2006 Edition, Section 18.2.3.2.1.)

2. A water supply approved by the county, capable of supplying the required fire flow for fire protection, shall be provided to all premises upon which facilities or buildings, or portions thereof, are hereafter constructed, or moved into or within the county. When any portion of the facility or building is in excess of 150 feet (45 720 mm) from a

Mr. Jared Chang
Page 2
July 20, 2010

water supply on a fire apparatus access road, as measured by an approved route around the exterior of the facility or building, on-site fire hydrants and mains capable of supplying the required fire flow shall be provided when required by the AHJ [Authority Having Jurisdiction]. (NFPA 1; UFCTM, 2006 Edition, Section 18.3.1, as amended.)

3. Submit civil drawings to the HFD for review and approval.

Should you have any questions, please call Acting Battalion Chief Gary Lum of our Fire Prevention Bureau at 723-7152.

Sincerely,

A handwritten signature in black ink, appearing to read "Kenneth G. Silva".

KENNETH G. SILVA
Fire Chief

KGS/SY:jl